

NOTES:

- 1. Pipe specifications: Drain pipe shall be a minimum of 4" diameter (6" minimum for runs of 500' or greater or as recommended by Soils Engineer). Pipe specifications shall conform to the Standard Specifications for Public Works Construction or as recommended by the Soils Engineer and approved by the City Grading Inspector.
- 2. Filler material shall meet the following specifications or as recommended by the Soils Engineer and approved by the City Grading Inspector.

SIEVE SIZ	Œ	PERCENTAGE PASSING
1"		100
3/4"		90-100
3/8"		40-100
No.4		25-40
No.8		18-33
No.30		5-15
No.50		0-17
No.200		0-3



No. 18542

CITY OF ORANGE

PUBLIC WORKS DEPARTMENT

CANYON SUBDRAIN

STANDARD PLAN No. 335