

SPAN S	В	STEEL SCHEDULE J-BARS			CURB
		Size	Spaning 0-C	Length	HEIGHT
2'-0"	3"	#3	7"	2'-9"	9.75"
2'-6"	"	"	"	3'-3"	"
3'-0"	**	n	"	3'-9"	"
3'-6"	"	»	6"	4'-3"	11
4'-0"	,,	"	5"	4'-9"	"
4'-6"	4"	"	6½"	5'-3"	10.75"
5'-0"	3)	"	5"	5'-9"	"
5'-6"))	"	4"	6'-3"	"
6'-0"	n	"	31/2"	6'-9"	"

TABLE 1

GENERAL NOTES:

- 1. Floor of Parkway Culvert shall have a steel trowel finish.
- 2. All exposed metal shall be galvanized after fabrication.
- 3. Span "S" will be determined from the required hydraulic capacity and limited to the dimension in Table I. (Max. Span = 6.0').
- 4. Reinforcing steel shall be 1" clear to inside of Culvert unless otherwise shown.

No. 18542 | Exp. 6-30-05 | Exp. 6-30

ANT CITY ENGINEER

4-2-04 CITY OF ORANGE

PUBLIC WORKS DEPARTMENT

STANDARD PLAN No. 312

PARKWAY CULVERT DETAILS AND NOTES