


NOTES:

1. Concrete shall have a minimum ultimate compressive strength at 28 days of 2500 p.s.i. Concrete may be pneumatically placed and shall conform to Section 303-2 of the Standard Specifications (Greenbook).
2. Reinforcing shall be 6"x6"x10ga. W.W.M. or approved equal.
3. Ground shall be pre-wetted to the satisfaction of the City Grading Inspector prior to placement of concrete. Curing compound shall be used when required by the City Grading Inspector.
4. Anchors shall be constructed in accordance with Standard Plan 333 (Sheet 2) when slope equals or exceeds 2:1.



9-16-04
DATE APPROVED

CITY OF ORANGE PUBLIC WORKS DEPARTMENT

STANDARD
PLAN No.
332

[Signature]
PUBLIC WORKS DIRECTOR/C.E.
[Signature]
ASSISTANT CITY ENGINEER

INTERCEPTOR DRAIN