

## **Building & Safety Services**

300 E. Chapman Ave. Orange, CA 92866 Office: 714 744-2225

## Eligibility Checklist for Expedited Electric Vehicle Charging Station Permit:

## **Multi-Family Dwellings**

Multi-ramily Dwellings				
Type of Charging Station(s)	Power Levels (proposed circuit rating)	Che	ck	one
Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps			
Level 2 - 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps			
Level 2 – 6.6kW (medium)	208/240 VAC at 40 Amps			
Level 2 – 9.6kW (high)	208/240 VAC at 50 Amps			
Level 2 – 19.2kW (highest)	208/240 VAC at 100 Amps			
Other (provide detail):	Provide rating:			
Permit Application Requireme	ents:			
A. Does the application include EV	CS manufacturer's specs and installation guidelines?	Υ		N
Electrical Load Calculation W  A. Is an electrical load calculation			Υ	
B. Based on the load calculation worksheet, is a new electrical service panel upgrade required?				
		Ш	Y	
required?	the electrical service panel upgrade?		Υ Υ	
required? 1) If yes, do plans include				
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose	the electrical service panel upgrade?		Υ	
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram?  Site Plan and Single Line Draw	the electrical service panel upgrade? ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 ed circuit card with electrical calculations included with  ving:		Y	
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram?  Site Plan and Single Line Draw A. Is a site plan and separate e with the permit application?	the electrical service panel upgrade? ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 ed circuit card with electrical calculations included with  ving:  lectrical plan with a single-line diagram included?		Y	
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram?  Site Plan and Single Line Draw A. Is a site plan and separate e with the permit application?  1) If mechanical ventilation	the electrical service panel upgrade? ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 ed circuit card with electrical calculations included with  ving: lectrical plan with a single-line diagram included		Y	
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram?  Site Plan and Single Line Draw A. Is a site plan and separate e with the permit application?  1) If mechanical ventilation requirements (CEC 625.9)	the electrical service panel upgrade? ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 ed circuit card with electrical calculations included with  ving: lectrical plan with a single-line diagram included? requirements are triggered for indoor venting 62 (B)), is a mechanical plan included with the	Y	Y	
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram?  Site Plan and Single Line Draw A. Is a site plan and separate e with the permit application?  1) If mechanical ventilation requirements (CEC 625.5 permit application?	the electrical service panel upgrade? ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 ed circuit card with electrical calculations included with  ving: lectrical plan with a single-line diagram included? requirements are triggered for indoor venting 62 (B)), is a mechanical plan included with the	□ Y	Y	
required?  1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram?  Site Plan and Single Line Draw A. Is a site plan and separate e with the permit application?  1) If mechanical ventilation requirements (CEC 625.8 permit application?  B. Is the site plan fully dimension 1) Showing location, size, and	the electrical service panel upgrade? ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 ed circuit card with electrical calculations included with  ving: lectrical plan with a single-line diagram included? requirements are triggered for indoor venting 62 (B)), is a mechanical plan included with the	□ Y □ Y □ Y	Y	

## Compliance with the California Electrical Code:

A. Does the plan include EVCS manufacturer's specs and installation guidelines?	T — v	Пи
B. Does the electrical plan identify the amperage and location of existing electrical	<del>                                     </del>	
service panel?	L Y	□N
I) If yes, does the existing panel schedule show room for additional breakers?		N
C. Is the charging unit rated more than 60 amps or more than 150V to ground?	☐ Y	□ N
If yes, are disconnecting means provided in a readily accessible location in line of site? (CEC 625.43)	☐ Y	□N
D. Does the charging equipment have a Nationally Recognized Testing Laboratory (NRTL) approved listing mark? (UL 2202/UL 2200)	□Y	$\square$ N
E. If trenching is required, is the trenching detail called out?	Y	
<ol> <li>Is the trenching in compliance with minimum cover requirements for wiring methods or circuits? (18" for direct burial per CEC 300.5)</li> </ol>	Y	Z
Compliance with California Green Building Standards Code:		
A. Do the CAL Green EV Readiness installation requirements apply to this project:		ПИ
1) Do the plans demonstrate conformance with mandatory measures for 10% of total parking spaces, for new multifamily dwellings provided for all types of parking facilities, to be electric vehicle charging spaces (EV spaces) capable of supporting future EVCS? (4.106.4.2)	Y	□N
2) Do the construction documents indicate the location of the proposed EV spaces where at least one is located in common use areas and available to all residents for use? (4.106.4.2.1) Calculations for the required number of EV spaces shall be rounded up to the nearest whole number.	☐ Y	□ N
<ul> <li>3) When EV chargers are installed, EV spaces required by Section 4.106.4.2.2, item 3 shall comply with at least one of the following options:         <ul> <li>a. The EV space shall be located adjacent to an accessible parking space that complies with CBC Chapter 11A, to allow use of the EV charger from the accessible parking space.</li> <li>b. The EV space shall be located on an accessible route, as defined by CBC Chapter 2, to the building.</li> <li>c. EV charging space(s) comply with Section 4.106.4.2.2, items 1, 2 and 3.</li> </ul> </li> </ul>	☐ Y	□ N
<b>tes:</b> This criteria is intended for an expedited EVCS permitting process. If any items are a please revise plans to fit within the eligibility checklist; otherwise the permit application through the standard plan review and approval process. Plan review commences is submittal with up to 3 business days for qualifying expedited projects and up to 10 business days for plant expedited projects.	ation m the day	ay go after
Electrical plans shall be completed, stamped and signed by a California Licensed Electrical contractor.	ctrical Er	ngineer
EVCS project review is limited to health and safety requirements found under local, stallaw. EVCS permit approval is not subject to approval of an association (as defined in the Civil Code).		
ject Address:		
plicant Signature:		
plicants Printed Name:		

Contractor's License Number and type: