



SECTION A - A

NOTES:

1. CONCRETE COLLAR SHALL MEET CURB AT SAME ELEVATION AS TOP OF CURB.
2. CONCRETE SHALL BE CLASS 420-C-2000 CONTAINING NOT LESS THAN FIVE SACKS PER CUBIC YARD.
3. GUARD POSTS SHALL BE INSTALLED PER STD. OWD-104 WHEN THERE IS NO CURB.

David D. Dief 1/31/2023
CITY WATER MANAGER

James B. 1/31/2023
CITY ENGINEER

John A. 1/31/2023
PUBLIC WORKS DIRECTOR

CITY OF ORANGE WATER DIVISION STANDARDS

FIRE HYDRANT CONCRETE COLLAR INSTALLATION

OWD STD. DWG.

OWD-103

SHEET 1 OF 1