



NOTES:

1. 4" STD. STEEL PIPE SHALL BE GALVANIZED COATED.
2. CONCRETE SHALL BE CLASS 420-C-2000 CONTAINING NOT LESS THAN FIVE SACKS PER CUBIC YARD.
3. GUARD POSTS SHALL BE INSTALLED PER STD. OWD-104 WHEN THERE IS NO CURB.

David Siof 1/31/2023
CITY WATER MANAGER

James 1/31/2023
CITY ENGINEER

John 1/31/2023
PUBLIC WORKS DIRECTOR

CITY OF ORANGE WATER DIVISION STANDARDS

FIRE HYDRANT GUARD POST INSTALLATION

OWD STD. DWG.

OWD-104

SHEET 1 OF 1